

Other data		
Start ramp trimmer TR3 (start-ramp)		0 4 s
Disable Time trimmer TR2 (CM-delay)		01s
Currentlimitation adjustable over DIP		0,5 5A
IxR compensation trimmer TR1 (IxR)	Rı	02,1 Ω
Dynamic brake (Armature short circuit)		Can be switched off
Installation orientation / Assembly		any / top-hat rail EN 50022
Installation place, typical		Switch cabinet
Storage temperature		-30 +85 °C
Permissible humidity		0 to 95 %, non-condensing
Weight		0,075 kg
Start up time		2 s
MTBF (SN29500, 40°C, rated load)		85,7 years
Hazardous substance norm		RoHS2
EMC interference immunity		EN 61326-1:2013-01
-		EN 61000-6-2:2005-08
EMC emitted interference, operation in industrial DC network		EN 61326-1:2013-01, Class A
EMC emitted interference, operation with power supply		EN 61326-1:2013-01, Class B
supply unit / power unit		KDR 120-24, Ott GmbH & Co. KG or comparable
Technical data: digital input		
High Signal typ.		U > 10 V
Low Signal typ.		U < 4 V
Impedance typ.	Rdi	15 kΩ
Technical data: digital output overcurrent		
"Ready"		GND (4,7kΩ Pull-Down)
"Overcurrent"		VCC
Current typ	IDO	700 mA
Short circuit-proof		Yes, self-limiting
Technical data: analog input		
Voltage range		0 10 V
Vcc tolerant		yes
Impedance typical	RAI	98,5 kΩ
Flammability		
Housing, terminals, printed circuit board		UL94V-0


Starting behavior

After applying supply voltage, the module M3-4Q-5-30 is ready for operation when the start up time has elapsed.

Description

The M3-4Q-5-30 module is a multi-functional motor controller for use in industrial environments. It ensures the switching on and off, as well as the controlled driving of motors. The motor's direction of rotation can be set via a digital input. An internal trimmer can be used to set the maximum speed. By means of an analog input the speed can be set between 0 to maximum speed. The dynamic brake can be deactivated over a digital input. The module has an adjustable starting ramp and current monitoring delay. The IxR compensation can be used to minimize load-dependent speed changes. The maximum motor current can be set by DIP switches. Additionally the motor current can be reduced through an analog input during operation. A digital input allowes to switch between the functions overcurrent shut-off and current limitation. By means of a further digital input, the module can be switched to 100% PWM speed.

Datasheet M3-4Q-5-30 06.34.002



5		6	7	8
digi "ov	tal output ⁄ercurrent" h-aktiv	analog input 010 V, "rotation speed"	Auxiliary voltage output +10V (PTC-Fuse) for 2 x 10kOhm potentiometer	Auxiliary voltage output +24 V 0,5 A max
1		2	3	4
digi	tal input	digital input	GND for external potentiometer	digital input
"dir	rection left	"direction right"	0,5 A max	"current limitation/overcurrent shutdown"
(p-	switch)	(p- switch)		(p- switch)
	,			
9		10	11	12
Mot	tor winding B	Motor winding A	digital input "disable dynamic brake (p- switch)	digital input "100 % PWM" (p- switch)
13		14	15	16
GN	D supply	+24 V supply +/-10 %	analog input 010 V "current limit"	Auxiliary voltage output +24 V

State table

direction "left" (1)	direction "right" (2)	disable dyn. braking (11)	Motor "A" (10)	Motor "B" (9)	Funktion
0	1	Х	VCC		run right
1	0	Х		VCC	run left
1	1	Х	GND	GND	dyn. braking
0	0	0	GND	GND	dyn. braking
0	0	1	open	open	off

0 = off 1 = on x = don't care

Function: Rotation speed control	Function: PWM100%
The maximum output speed can be set or limited with the trimmer TR4. The speed setting itself is given through the analog input voltage at terminal (6) in the range of 0 to 100% adjustable via trimmer TR4. An analog voltage must be applied at terminal (6) in order to turn the motor. 0 V at terminal (6) equals to 0 rpm. If the module should operate only with the internal set speed, terminal (6) must be connected to + 10V / VCC, e.g. connect terminal (6) to terminal (7).	 If applying a HIGH signal at terminal (12), the motor output will be directly set to 100% PWM (speed). Regardless of any setting at TR4 or analog input at terminal (6). In case of a running motor. The ramp up function is not active. The current monitoring delay is started, so the current monitoring is not active for that time. If a HIGH signal at terminal (12) is set before setting the direction. The module ramps up with the adjusted ramp time on trimmer TR3 to 100% PWM (speed).

Function: dynamic brake	Function: short circuit detection					
The module stops the motor with "dynamic brake" function by default. It can be deactivated by applying a HIGH signal at terminal (11). If dynamic braking is active, the motor winding is switched to GND at both terminals when switched off. The motor is stopped with armature short circuit braking. If dynamic braking is not active, the motor stops with no braking. If both rotation direction inputs (terminals 1 and 2) are simultaneously high, the motor always stops with a dynamic brake. In this case the brake setting at the digital input (11).	When the module detects a short circuit on the motor output, the motor switches off without dynamic braking. The motor can be restarted by means of a reset and fresh setting of any input of direction of rotation.					
Function: overcurrent shut-off / current limitation	Functi	on: setti	ng the r	naximur	n motor current	
The module can be operated in overcurrent shut-off or current limitation mode. The mode is given by the digital input at terminal (4): overcurrent shutdown: If the digital input is not active (not connected), the module is in the overcurrent shut-off mode. If the motor current exceeds the adjusted maximum motor current, the module turns off the motor. The motor can be restarted by resetting any of the two inputs of direction of rotation. current limitation: When the digital input is applied with HIGH signal, the module is in current limitation mode. In this mode, the motor current is limited to the adjusted maximum value.	switch (15). The ma DIP sw then gi termina value. If the m maximutermina	on the m aximum p ritches 1- ven by th al (15), in nodule sh um moto al 15 mus	odule ar permissil 4 (see ta e applie the rang nould be r current st be con	nd the an ole motor able). The d voltage ge from (operated setting o inected to	Idjusted via the DIP alog input on termina r current is set via the e motor current itself e at analog input on 0 to 100% of the pres d only with the of the DIP switches, to o +10V or to VCC, erminal (16) or (7)).	nal ne If is eset
					[A]	
	Off	Off	Off	Off	0,5	
	On	Off	Off	Off	0,75	
	Off	On	Off	Off	1	
	On	On Off	Off	Off	1,25	
	Off	Off Off	On	Off Off	1,5	
	On Off		On On	Off Off	1,75 2	
	On	On <mark>On</mark>	On <mark>On</mark>	Off	2,25	
	Off	Off	Off	On	2,25	
	On	Off	Off	On	2,75	
	Off	On	Off	On	3	
			1			
	On	On	Off	On	3,25	
	_	On Off	Off <mark>On</mark>	On On	3,25 3,5	

Function: Start ramp	Function: IxR compensation
After setting any direction of rotation, the module ramps up the speed until the set value is reached. The gradient of the start ramp can be adjusted via trimmer TR3.	The module has a built in IxR compensation function. This function can be used to compensate load depending speed changes of the motor. The gain factor is set with trimmer TR1. !ATTENTION! Please use this function carefully! Incorrect gain factors may cause instable operation!

Off

On

On

On

On

On

On

On

On

4

5

4,5

On


Off


On

Datasheet M3-4Q-5-30 06.34.002

Function: current monitoring delay		Function: Overcurrent output			
The current monitoring delay is adjustable by trimmer TR2. After setting any direction of rotation input the		The overcurrent output indicates by a HIGH signal:			
	overcurrent shutdown is disabled for the adjusted time.		In current limitation mode:		
The current mo	The current monitoring delay is also started when setting		As long as the motor current is limited.		
	the PWM100% digital input on terminal (12) to HIGH				
signal.				ercurrent shut-off mode	
			As soo stoppe	on as over current is detected and motor is	
_					
Device status	Device status		Display elements		
	The module status is displayed via the LEDs on the		Module errors are displayed as flashing sequences. The		
module front pla	module front plate.		end of the sequence is indicated by a pause of 1		
			second.		
LED1	LED2	meaning	The number of flashes indicates the error number.		
red	green				
Off	On	Module is operational	Modul	e error 1	
On	flashing	overcurrent shut-off	1	overcurrent	
		active and overcurrent	2	Over-temperature	
-	-	detected	3	short circuit detected	
On	On	Current limitation active	4	overvoltage	
		and overcurrent	5	overload	
		detected	6	Under-temperature	
On/Off	flashing	Module error 1 (see	7	Low supply voltage	
		table)	8		
flashing	flashing	Internal Error			

Dimensional drawing





A = 70,4 mm; B = 22,5 mm; C = 85 mm

Safety notes

Maximum operational data

The maximum operating data must not be exceeded.

Installation

The installation and start-up must be performed by specialist personnel exclusively.

All affected components must be disconnected from the mains.

Start-up

For the first start-up, the motor should be operated without load.

Risk of death

Do not touch live parts after switching on!

The assembly must be operated exclusively on safety extra-low voltage. With operation on extra-low voltage (e.g. via autotransformer), death or injury can occur.

Fire protection

The assembly must be installed in a switch cabinet, which is suitable as a fire protection enclosure.

The assembly must be safeguarded with a pre-fuse aligned with the nominal data.

Field of application

The assembly may only be used as intended.

Other components must be checked for their approvals and regulations.

Safety devices

An additional safety device must be used to bring the system into a safe state in case

of a cable break, incorrect operation, failure of the control/controller unit.

EMC / EMI

The wiring must be done according to EMC / EMI standards. If necessary, shielded cables and EMC suppressors must be used for the connected consumer.

For operation in a public low-voltage distribution network, the module must be supplied with an approved AC adapter.

If the module is supplied with an AC adapter, other equipment, operated on the same power supply, must be suitable for use in industrial environments.

Repairs

Repairs must be performed by authorised persons exclusively. With unauthorised opening,

the warranty cover is voided and this may also result in danger for the user and for the system.

Maintenance

The assembly is wear-free by design.

For modules **with** cooling openings free air circulation must be checked at the cooling openings or on the housing at regular intervals. If necessary, the cooling holes / the housing must be cleaned.

Good ventilation must be ensured.

contact details



ready-to-use motor control solutions electronics design & manufacturing

KALEJA GmbH Strübelweg 14 73553 Alfdorf, Germany Phone: +49 7172 93711 0 Fax: +49 7172 93711 90 E-Mail: info@kaleja.com www.kaleja.com